

Pulsed optical pumping in a Rb vapour cell using a compact magnetron-type microwave cavity

Songbai Kang^{1,2}, Christoph Affolderbach¹, Florian Gruet¹,
Claudio E. Calosso³, Gaetano Mileti¹

¹Laboratoire Temps-Fréquence, University of Neuchâtel, Neuchâtel, Switzerland

²Key Laboratory of Atomic Frequency Standards, Wuhan Institute of Physics and Mathematics of Chinese Academy of Sciences, Wuhan, China

³Istituto Nazionale di Ricerca Metrologica (INRIM), Torino, Italy

Email: christoph.affolderbach@unine.ch

A high-performance Rb cell clock based on pulsed optical pumping (POP) with optical detection has been demonstrated previously, showing excellent clock stabilities on both the short-term and up to few days timescales¹. A compact magnetron-type microwave cavity has previously been developed for a Rb atomic clock² based on conventional continuous-wave double-resonance (DR) interrogation. This magnetron-type cavity shows a homogenous microwave field distribution while having a cavity volume 3 times smaller than the cavity used in¹, which makes it interesting for the realization of a POP clock with reduced physics package size.

In this communication we report on the evaluation of pulsed optical pumping with our magnetron-type cavity. Using the pulsed technique and optical detection, high-contrast Ramsey fringes were observed, see Fig.1. The central fringe of the Ramsey signal has a linewidth of ≈ 150 Hz and contrast of $\approx 40\%$. Under these conditions, the shot-noise limit is estimated at a level of $1 \times 10^{-13} \tau^{-1/2}$ and is expected to be further improved, which shows the great potential of a POP clock based on the compact magnetron-type cavity. Further results will be presented at the conference.




Fig. 1: Ramsey signal observed with optical detection. The central fringe has a linewidth of about 150Hz and contrast of about 40%.

This work was supported by the Swiss National Science Foundation (SNSF) and the European Metrology Research Programme (EMRP project IND55-Mclocks). The EMRP is jointly funded by the EMRP participating countries within EURAMET and the European Union.

¹ S.Micalizio, C. E. Calosso, A. Godone and F. Levi, “Metrological characterization of the pulsed Rb clock with optical detection”, *Metrologia* 49, pp. 425-436 (2012).

² C. Stefanucci, T. Bandi, F. Merli, M. Pellaton, C. Affolderbach, G. Mileti, A. K. Skrivervik, “Compact microwave cavity for high performance rubidium frequency standards”. *Rev. Sci. Instrum.* **83**, 104706, 2012.